

Nassau County Board of County Commissioners  
Emergency Certification Form

Department: Nassau Amelia Utilities

Date: 2-8-2017 2/21/17

Account: 71500535-546535

Describe Emergency Circumstance (How is this an immediate danger to public health, safety or welfare or what substantial loss will the County incur by not acting immediately?):

The sewer main line on Amelia Parkway has been damaged by directional drilled conduits. The roadway has collapsed opening a hole over five feet deep and four feet in diameter down to the sewer line. This line takes all the flow from most of the Summer Beach development as well as the Ritz Carlton Hotel. Sewer overflow and backup could occur at any time. The conduits shot through the sewer main are most likely electric service lines.

Recommended Action:

I have contacted J.B.Coxwell Contracting for an emergency repair. They are sending a superintendent to assess the situation and arrange for repairs.

Vendor Contacted: J.B.Coxwell Contracting


Vendor Phone: 904-786-1120

Cost: estimated \$16,358.91

I certify that the existing circumstances meet the requirements of an emergency purchase as stated in the Nassau County purchasing policy. I have made every effort to encourage competition and seek the best value for Nassau County.

 2/21/17  
Department Head Signature revised

Approval:

 2-22-17  
County Manager Date

\_\_\_\_\_  
Chairman (if over \$50,000)

Date of Board meeting (if applicable):

2/21/17