

#### General Notes and Specifications

- 1. Prior to construction the landscape contractor shall be responsible for locating all underground utilities and shall avoid damage to all utilities during the course of the work. The landscape contractor is responsible for repairing any and all damage to utilities, structures, site appurtenances, etc., which occurs as a result of the landscape construction.
- When conditions detrimental to plant growth are encountered, such as rubble fill, adverse drainage conditions or obstructions, notify owner's representative
- 3. All plants must be healthy, vigorous material, free of pests and disease.
- 4. All trees, palms, and shrubs shall be grade "Florida Fancy" per Grades and Standards For Nursery Plants (parts one and two), available through Florida Dept. of Agriculture and Consumer Services. 5. All plant material must be approved by the Landscape Architect before
- the plant material is installed. 6. Any changes to the plant material (size, type, etc..), irrigation or any other deviations from the plans must be approved by the Landscape Architect
- prior to the change being implemented by the contractor. The contractor must provide written proof of authorization for any changes. 7. All plants to be field grown or container grown as indicated on plant list.
- Store plants in shade and protect from weather. If plants cannot be planted immediately upon delivery, properly protect them with soil, wet peat moss, or,in a manner acceptable to owner's rep. Do not remove container grown stock from containers until planting time. Protect roots of plant from drying or other possible injury. Keep plant ball moist at all times.
- 8. All plants shall be triangular spaced.
- 9. Obtain agronomic soils test for all planting areas and tree pits prior to excavation of tree pits. Tests shall be performed by an approved soils testing laboratory and shall include fertility and suitability analysis with written recommendations for soil amendments, fertilizer and chemical conditioner application rates for soil preparation, planting backfill mix, and post maintenance fertilization program. Submit a copy of soils report to owner's rep. and landscape architect.
- 10. Add soil amendments as recommended by soil test in quantities necessary to bring soil mixture to pH rating of between 5.5 and 6.0. Minerals used for pH correction shall be commercially produced for this purpose.
- 11. All plants and planting areas must be completely mulched as specified with three (3) inches of organic mulch. Provide 4" minimum clearance of mulch from all shrub trunks and 6" minimum clearance from all tree trunks.
- 12. The landscape contractor is responsible for verifying all quantities shown on these plans, before pricing the work.
- 13. The planting shall be done in accordance with acceptable horticultural practices. This is to include proper planting mix, plant and tree pit preparation, pruning, staking or guying, wrapping, spraying, fertilization, planting, and adequate maintenance throughout the required maintenance period.
- 14. The landscape contractor is responsible for fully maintaining all planting (including but not limited to: pruning, watering, fertilizing, cultivating, weeding, mowing, mulching, tightening and repairing of guys, resetting plants to proper grade or upright position, restoration of plant saucer, and furnishing and applying such sprays as necessary to keep free of insects and diseases. The landscape contractor's responsibility for maintenance (exclusive of replacement within the guarantee period) shall terminate one year from the date of final acceptance by owner and landscape architect.
- 15. All trees, palms, shrubs and plant material shall be warranted for a period of one year after date of completion and acceptance of the entire project Final acceptance of all landscaping under this contract shall constitute the beginning of the guarantee period. Replace, in accordance with the drawings and specifications, all plants that are dead or, as determined by the owner's representative, are in an unhealthy or unsightly condition, and have lost their natural shape due to dead branches, or other causes due to the contractor's negligence. Furnish and plant replacements which comply with requirements shown and specified. Warrant all replacement plants for one year after installation. The cost of such replacement(s) is at the contractor's expense.
- 16. All plants are subject to approval by the owner's representative. Prior to planting, all trees and palms must be approved by the owner or owner's rep.
- 17. Standards set forth in "American Standard for Nursery Stock" represent guideline specifications only and shall constitute minimum quality requirements for plant
- 18. At the conclusion of this planting, if the owner's rep. or owner has reason to believe that the plants are not of the specified grade, he will request a re—grading or inspection, and such evidence will be the basis for requesting replacement of plants and for legal or other action according to law, should this become necessary.
- 19. All planting beds to be treated with pre-emergent weed control prior to planting.
- 20. Contractor is to check the site weekly to insure all plant material is healthy and well watered.
- 21. All disturbed areas to be sodded or seeded with Paspalum notatum as noted.

LAWN AREA	PAVEMENT
SOIL AND ROOT LAYER  TOPSOIL AS SPECIFIED  FINISHED  GRADE	(TYPICAL)  1/2" "EDGER" SMOOTH, CLEAN & PARALLEL TO PAVEMENT
CULTIVATED SOIL	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
UNDISTURBED SOIL	
	TALL SOD SUCH THAT TOP OF

INSTALL SOD SUCH THAT TOP OF SOIL & ROOT LAYER IS LEVEL WITH TOP OF PAVEMENT

$\bigcirc \bigcirc \bigcirc$	
200	DETAIL

PLA	NT S	CHEDULE ANCHOR CHURCH			
CODE	QTY	COMMON / BOTANICAL NAME	SPACING	SPECIFICATIONS	SPECIES %
TREES					
AR	2	Red Maple / Acer rubrum	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
BN	2	River Birch Multi-Trunk / Betula nigra	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
7	2	Eastern Red Cedar / Juniperus virginiana	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
MG	2	Southern Magnolia / Magnolia grandiflora	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	7%
av	1	Southern Live Oak / Quercus virginiana	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
TD	2	Bald Cypress / Taxodium distichum	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
UAF	2	Florida Elm / Ulmus americana floridana	AS SHOWN	3" cal. 10' - 12' ht. , 5' - 6' spd.	14%
CODE	aty	COMMON / BOTANICAL NAME	SPACING		
Total T SHRUBS	rees: 6	64			
MC	241	Pink Muhly / Muhlenbergia capillaris	36" o.c.	24" ht. x 24" spd. minimum full & dense	44% native
9	313	Dwarf Walter's Viburnum / Viburnum obovatum 'Dwarf Walter's'	30" o.c.	24" ht. × 24" spd. minimum full ∉ dense	56% native

# NOTES:

- 1. MULCH ALL PLANTING BEDS WITH 3" ORGANIC MULCH.
- 2. ALL DISTURBED AREAS NOT OTHERWISE LANDSCAPED SHALL BE SODDED WITH BAHIA SOD.
- 3. ALL PLANT MATERIAL TO BE FLORIDA NO. 1 QUALITY OR BETTER.
- 4. NO SUBSTITUTIONS WITHOUT PRIOR WRITTEN CONSENT OF THE LANDSCAPE ARCHITECT
- 5. ALL TREES AND PLANTS SHALL MEET MINIMUM SPECIFIED SIZES IN INCHES AND FEET, REGARDLESS OF CONTAINER SIZE INDICATED. WHERE DIFFERRENCES OCCUR, THE LARGER SPECIFICATION SHALL PREVAIL
- 6. CONTRACTOR TO VERIFY ALL QUANTITIES


### ORDINANCE CHAPTER 366 SCHEDULE AND IRRIGATION REQUIREMENTS:

MARCH-NOVEMBER (DAYLIGHT SAVINGS TIME)

NOVEMBER - MARCH (STANDARD TIME)

ONE TIME PER WEEK.


- NO WATERING FROM 10AM TO 4 PM ODD NUMBER ADDRESSES OR THOSE ENDING WITH N-Z OR NO ADDRESS MAY WATER ON
- WEDNESDAY AND SATURDAY EVEN NUMBER ADDRESSES OR THOSE ENDING
- WITH A-M MAY WATER ON THURS, AND SUNDAY NON-RESIDENTIAL ADDRESSES MAY WATER
- ON TUESDAY AND FRIDAY APPLY UP TO 3 - INCH OR LESS OF WATER EACH CYCLE
- NO WATERING FROM 10 AM TO 4 PM ODD NUMBER ADDRESSES, OR THOSE ENDING WITH N-Z OR NO ADDRESS MAY WATER ON
- EVEN NUMBER ADDRESSES OR THOSE ENDING
- WITH A-M MAY WATER ON SUNDAY NON-RESIDENTIAL ADDRESSES MAY WATER
- ON ONLY ON TUESDAY - APPLY UP TO  $\frac{3}{4}$  - INCH OR LESS OF WATER




### **NASSAU COUNTY NOTES:**

Plant material. All installed trees, shrubs and groundcovers shall conform to the standards for Florida Grade #1 or better according to the current edition of "Grades and Standards for Nursery plants" published by the Florida Department of Agriculture and Consumer Services, Division of Plant Industry. Synthetic or artificial trees, shrubs, groundcovers or vines are not acceptable substitutes. In choosing plant materials, consideration should be given to the amount of sun or shade, the wetness or dryness of the soil, the effects of salt spray (where applicable), the amount of irrigation required and the mature size and spatial needs of plants chosen. 1. The minimum number of trees required by this section shall be either qualifying existing trees preserved on-site or more than one species listed in Tables 37-1 or 37-2. Trees planted in addition to these minimum requirements of this section may be any species of canopy tree or palm except for the prohibited species listed herein. In order to prevent a monoculture, new landscaping should not include more than fifty (50) percent of any one genus or twenty-five (25) percent of any one species. All trees shall be planted in a minimum dimension of ten (10) feet. This minimum planting area must be free of all pavement and vehicle overhang in order to prevent possible tree damage. All trees shall have a minimum trunk diameter, measured six (6) inches above ground level, in accordance with Table 37-3.

- 2. Shrubs shall have a minimum height of eighteen (18) inches when planted. When planted as a hedge, the maximum spacing is 30 inches on center. All shrubs used for visual screening shall be of a plant species that is capable of reaching a height of four (4) feet within twenty-four (24) months under normal growing conditions. Shrubs used as accent ground cover and vines may vary in size depending on the type of plant material and the desired effect. 3. Groundcovers shall be planted in such manner as to present a finished appearance and complete coverage within one (1) year after planting.
- 4. LDC Section 37.05 (B)(I) -All trees shall be planted in a minimum dimension of ten (10) feet. This minimum planting area must be free of all pavement and vehicle overhang in order to prevent possible tree damage.
- 5. LDC Section 37.05 (B) -All trees planted shall be staked or guyed for a period of at least six (6) months in accordance with the adopted planting detail.
- 6. LDC Section 37.05 (H)(4)-All planting areas shall be mulched with approximately three inches of organic mulch, such as pine bark or shredded hardwood chips.
- 7. LDC Section 37.05 (K)(2) -All buffer areas required as part of a development plan, whether in common or private ownership, shall be the responsibility of that development's property owners' association. Where there is no property owners' association, such landscaped areas shall be the responsibility of the property owner.
- 8. LDC Section 37.05 (K)(3) -Trees on developed properties may be pruned to maintain shape and promote their shade-giving qualities. They should be pruned to remove diseased or dying portions in areas where falling limbs could be a hazard to people or property. Lower limbs may be removed to provide clearance. In addition, trees located in association with vehicular use areas shall also be pruned to allow a seven-foot clearance from ground level to avoid potential for damage or injury to pedestrians and cleared to thirteen (13) above pavement level for vehicles. However, the excessive pruning or pollarding of trees into round balls of crown or branches resulting in an unnecessary reduction of shade is prohibited and may require supplemental plantings. All pruning shall be done following the American National Standard for Tree Care Operations "Tree, Shrub and Other Woody Plant Maintenance - Standard Practices."
- 9. LDC Section 37.05 (E)(I) -At the intersection of two (2) streets, all landscaping within that area defined by the Florida Department of Transportation sight triangle, as outlined in the FDOT Design Standards for Design, Construction, Maintenance and Utility Operations on the State Highway System shall be installed and maintained below three (3) feet in height or above eight (8) feet in height.
- 10. LDC Section 37.05 (E)(2) -When a driveway intersects a right-of-way, clear unobstructed cross visibility shall be provided within the site triangle formed by such intersection. The sight triangle shall be measured from the point of intersection, fifteen (15) feet along the access way and then fifteen (15) feet along the right-of-way, with the third side being a line connecting the two (2) points. Cross visibility within the sight triangle shall be unobstructed between the height of three (3) feet and eight (8) feet measured from the ground line. Trees and palms shall have their limbs and foliage trimmed in a manner that no limbs or foliage will extend in to the cross visibility area. To ensure proper visibility at the intersection of access ways with public rights-of-way, excluding properly trimmed trees as previously stated; only ground cover type plants shall be allowed within the sight triangle.



SHRUB & GROUNDCOVER PLANTING DETAIL




DATE : <u>December 6, 2023</u> PROJECT NO. : 2023.95 DESIGNED BY : KSR

DRAWN BY : KSR CHECKED BY : KSR

SHEET TITLE

PLANTING



VALVE SCHEDULE ANCHOR CHURCH									
JMBER	MODEL	SIZE	TYPE	GPM	DESIGN PSI	FRICTION LOSS	VALVE LOSS	PSI	PRECIP
	Hunter ICV-G-FS (Zone Valve)	["	Area for Dripline	14.56	40	1.54	3	44.5	0.71 in/h
	Hunter ICV-G-FS (Zone Valve)	1"	Bubbler	6.5	30	9.74	2.65	42.4	1.7 in/h
	Hunter ICV-G-FS (Zone Valve)	1"	Area for Dripline	16.25	40	2.84	3	45.8	0.71 in/h

SYMBOL	MANUFACTURER/MODEL	QTY	ARC	PSI	GPM	RADIUS
2W	Hunter PCB	14	360	30	0.50	3'
SYMBOL .	MANUFACTURER/MODEL/DESCRIPTION	aty				
	Area to Receive Dripline  Hunter PLD-10-18  In-Line Pressure Compensating Landscape  Dripline with Built-In Check Valve. 1.0 GPH  emitters at 18" O.C. Dripline laterals spaced at  18" apart, with emitters offset for triangular  pattern. UV Resistant. Use PLD-LOC fitting or  barbed fittings.	2,729 l.f.				
YMB0L	MANUFACTURER/MODEL/DESCRIPTION	QTY				
	Irrigation Lateral Line: PVC Class 315 SDR 13.5 SDR 13.5 1/2" and 3/4" lines	332.5 l.f.				
	Irrigation Lateral Line: PVC Class 160 SDR 26 SDR 26 for all 1" and larger lateral lines	502.8 l.f.				
	MAINLINE Irrigation mainline, Schedule 40 PVC pipe 1 1/4" size.	1,100 1.f.				
(2") ==	SLEEVING Schedule 40 PVC, 2" Minimum, Size as specified on plan	27.8 l.f.				
1	Hunter series ICV-101G-FS-AS-ADJ (1" valve) Location shown for graphic clarity	I				
1	Hunter ICZ-IOI-XL (Drip Zone Valves) I" Plastic Electric Remote With Filter Sentry. Each Drip Zone to Have: Flush Valve, Eco Indicator, Air Relief Tubing.	2				
M	MASTER VALVE Hunter series ICV-101G-FS-AS-ADJ (1" valve) Location shown for graphic clarity					
BF	BACKFLOW DEVICE Wilkins 950XLT- 1" or equal Location shown for graphic clarity					
WELL H	EXISTING WELL  Contractor to verify pressure and gpm rates to match valve schedule, adjust zones as needed.	I				
FM	FLOW SENSOR HUNTER, HC-100-Flow-B (1" size) LOCATIONS SHOWN FOR CLARITY ONLY					
©	CONTROLLER  Hunter series PHC-12 (12 Zone) Install with Mini-Clik rain sensor.  LOCATION SHOWN FOR CLARITY ONLY					

Irrigation Contractor shall be responsible for all applicable fees and permits.

All PVC pipe connection shall be glued together per ASTM D 2855, two step method.

All Pipe and Wire under paving shall be placed in Schedule 40 P.V.C. Sleeves for the full pavement coverage length and shall be at least 24" below grade.

Mainlines shall be buried to provide a minimum cover of 18", while all Lateral lines shall have a minimum of 12".

The Contractor should take care to reroute piping as necessary to avoid plant or tree roots.

All Sprinklers shall be site adjusted to prevent water overthrow onto building surfaces and walkways.

All Control Wiring to be 14/1 U.F. direct burial.

Install a "MiniClik" rain sensor device. Verify location with Owners Representative.

Install Backflow Preventer in an inconspicuous location such as shrubbery. Location shown for graphic clarity purposes only.

Contractor responsible for 100% irrigation coverage

All irrigation risers to be painted black

Mainline location shown for graphic clarity purposes only.

Valve box location shown for graphic clarity purposes only.

Irrigation system designed to not exceed 5 feet per second flow through any piping. Any deviation from design upon installation voids these drawings and shall be done so as to not exceed 5' per second through any piping as well.

Irrigation water shall be free of particulates larger than 10 micron or .01 micrometers.

A & X LAND PLANNING & DESIGNATION OF THE PROPERTY OF 19692

541798 U.S. HIGHWAY NO.

DATE: December 6, 2023

PROJECT NO.: 2023.95

DESIGNED BY: KSR

DRAWN BY: KSR


CHECKED BY: KSR

SCALE: N.T.S.

SHEET TITLE

IRRIGATION DETAILS

 $\frac{|-2|}{2}$ 






ORDINANCE CHAPTER 366 SCHEDULE AND IRRIGATION REQUIREMENTS:


## MARCH-NOVEMBER (DAYLIGHT SAVINGS TIME)

- NO WATERING FROM 10AM TO 4 PM
- ODD NUMBER ADDRESSES OR THOSE ENDING WITH N-Z OR NO ADDRESS MAY WATER ON WEDNESDAY AND SATURDAY
- EVEN NUMBER ADDRESSES OR THOSE ENDING WITH A-M MAY WATER ON THURS. AND SUNDAY
- NON-RESIDENTIAL ADDRESSES MAY WATER ON TUESDAY AND FRIDAY
- APPLY UP TO  $\frac{3}{4}$  INCH OR LESS OF WATER EACH CYCLE

## NOVEMBER - MARCH (STANDARD TIME)

- NO WATERING FROM 10 AM TO 4 PM
- ODD NUMBER ADDRESSES, OR THOSE ENDING WITH N-Z OR NO ADDRESS MAY WATER ON SATURDAY
- EVEN NUMBER ADDRESSES OR THOSE ENDING WITH A-M MAY WATER ON SUNDAY
- NON-RESIDENTIAL ADDRESSES MAY WATER ON ONLY ON TUESDAY
- APPLY UP TO 3 INCH OR LESS OF WATER ONE TIME PER WEEK.





DATE : December 6, 2023

IRRIGATION

DETAILS

PROJECT NO. : 2023.95


DESIGNED BY : KSR

DRAWN BY :\_ KSR

CHECKED BY : KSR

SCALE : N.T.S.

SHEET TITLE



1) FINISH GRADE

2 10" ROUND VALVE BOX

AIR/VACUUM RELIEF VALVE

4 3/4"MPT x 1/2"FPT BUSHING


(7) BRICK SUPPORTS (3)


 $^{\circ}$  (5) dripline tubing


6 ADAPTER TEE


8 3/4" GRAVEL SUMP

AIR RELIEF TUBING










1) SUPER JUMBO VALVE BOX 2 FINISH GRADE DRIP ZONE KIT 3 MODEL ICZ-151-40 WITH FILTER (TIP 45 DEGREES) REGULATOR 40 PSI (4) WATERPROOF CONNECTORS (2) (5) 18-24" COILED WIRE (6) SCH 80 T.O.E. NIPPLE (7) MAIN LINE PIPE & FITTINGS (8) BRICK SUPPORTS (7) (9) 3/4" MINUS WASHED GRAVEL (10) LATERAL PIPE AND FITTINGS (11) PVC SLIP UNIONS (2)

SHEET TITLE

IRRIGATION DETAILS

S H E E T



ICZ-151-40 DRIP CONTROL KIT

Comiter IRRIGATION DETAIL

DATE: December 6, 2023 PROJECT NO. : 2023.95 DESIGNED BY : KSR DRAWN BY : KSR CHECKED BY : KSR SCALE : N.T.S.