

SECTION 00 65 16

CERTIFICATE OF SUBSTANTIAL COMPLETION

Project: Part A – Lift Station No. 1 and Part B – Lift Station No. 3 Replacement

Purchase Order No.: _____ Contract No.: CM2301

This Certificate of Substantial Completion applies to:

☒ All work under Contract ☐ Portion of work described as follows:

The Work to which this Certificate applies has been inspected by authorized representatives of the COUNTY and the CONTRACTOR and that Work is hereby declared to be substantially complete in accordance with the Contract Documents on : March 2, 2017.

DATE

A tentative list of items to be completed or corrected is attached hereto. This list may not be all-inclusive, and the failure to include an item in it does not alter the responsibility of CONTRACTOR to complete all the Work in accordance with the Contract Documents. The items in the tentative list shall be completed or corrected by CONTRACTOR within 60 days of the above date of Substantial Completion.

The date of Substantial Completion is the date upon which all guarantees and warranties begin.

SIGNED:

NASSAU COUNTY CONSTRUCTION INSPECTOR / Parsons Brinckerhoff, Inc.

By: [Signature] DATE: 3/2/17

NASSAU COUNTY PROJECT MANAGER

By: Rebecca [Signature] DATE: 4/19/17

NASSAU-AMELIA UTILITIES REPRESENTATIVE

By: [Signature] DATE: 4-27-17

ENGINEER OF RECORD:

By: M. Scott Richards DATE: 4/20/2017

CONTRACTOR:

By: Jeremy Rowell DATE: 3/14/17

**TENTATIVE LIST OF ITEMS TO BE COMPLETED OR CORRECTED
(PUNCH LIST)**

Date: 3/2/2017 Contract No.: CM2301 Purchase Order No.: _____

Project: Part A – Lift Station No. 1 and Part B – Lift Station No. 3 Replacement

Contractor: Rowell Contracting, Inc.

This list may not be all-inclusive, and the failure to include an item does not alter the responsibility of the CONTRACTOR to complete all the Work in accordance with the Contract Documents.

| <u>NO:</u> | <u>ITEM:</u> |
|------------|--|
| <u>1</u> | <u>LS 1 – Paint in check valves</u> |
| <u>2</u> | <u>LS 1 – Install pump name plates</u> |
| <u>3</u> | <u>LS 3 – Install pump name plates</u> |
| <u>4</u> | <u>LS 1 – Touch up paint on valves</u> |
| <u>5</u> | <u>LS 3 – Touch up paint on valves</u> |
| <u>6</u> | <u>LS 1 – Restore grass on site</u> |
| <u>7</u> | <u>LS 3 – Restore grass on site</u> |
| <u>8</u> | <u>LS 1 – Touch up paint at check valve where rust is bleeding through</u> |
| <u>9</u> | <u>LS 1 – Clean up yard inside fence</u> |
| <u>10</u> | <u>LS 1 – Clean aluminum hatch</u> |
| <u>11</u> | <u>LS 3 – Clean aluminum hatch</u> |
| <u>12</u> | <u>LS 1 – Submit as-builts for pipe and structures</u> |
| <u>13</u> | <u>LS 3 – Submit as-builts for pipe and structures</u> |
| <u>14</u> | <u>LS 1 – Install sod in R/W</u> |
| <u>15</u> | <u>LS 3 – Install sod in R/W</u> |
| <u>16</u> | <u>LS 1 – Remove PVC pipe to access WM for as-built elevations</u> |
| <u>17</u> | <u>LS 1 – Repair scratch on light pole</u> |
| <u>18</u> | <u>LS 3 – Seal extra conduit at demarcation box</u> |
| <u>19</u> | <u>LS 3 – Touch up fence</u> |
| <u>20</u> | <u>LS 1 & 3 – Shop Drawings for new pumps</u> |
| <u>21</u> | <u>LS 1 & 3 – Submit O&M Manuals for pumps</u> |

___22___ Submit Certifications, Warranties, and required forms prior to final acceptance

___23___ Correction of any other deficiencies found prior to final acceptance_____

END OF SECTION